

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

(WATER ANALYSIS REPORT)

REF. NO:- 147. SAMPLE PROVIDED BY:- Sanskriti KMV School

Tanda Road, Jalandhar.


REF. DT. 16/3/23 SAMPLE COLLECTED:-

| SR. NO. | TEST | REQUIRED LIMIT IS10500 | SAMPLE (1) | SAMPLE (2) | SAMPLE (3) | SAMPLE (4) |
|---------|-------------------------------------|---------------------------|---------------|---------------|---------------|---------------|
| 1 | COLOUR | 5 HAZEN | Colourless | | | |
| 2 | ODOUR | UNOBJECTIONABLE | Odourless | | | |
| 3 | TASTE | AGREEABLE | Normal | | | |
| 4 | PH | 6.5-8.5 | 6.7 | | | |
| 5 | TOTAL HARDNESS AS CaCO ₃ | 300 mg/l | 110 | | | |
| 6 | DISSOLVED SOLIDS(TDS) | 500 ppm | 151 | | | |
| 7 | ALKALINITY | 200 mg/l | 90 | | | |
| 8 | CALCIUM AS Ca ⁺⁺ | 75 mg/l | 12.0 | | | |
| 9 | IRON | 0.3 mg/l | 0.1 | | | |
| 10 | CHLORIDE | 250 mg/l | 280 | | | |
| 11 | SULPHATE | 150 mg/l | - | | | |
| 12 | NITRATES | 4.5 mg/l | 0.1 | | | |
| 13 | RESIDUAL CHLORINE | 0.2 mg/l | N/A | | | |
| 14 | FLUORIDE | 1.0 mg/l | N/A | | | |
| 15 | LEAD | 0.05 mg/l | N/A | | | |
| | BACTERIAL TEST | | | | | |
| | TOTAL COLIFORM COUNT | | / | | | |
| | BY MPN METHOD PER 100ML | | N/A | | | |
| | TOTAL E-COLI COUNT | | / | | | |
| | BY MPN METHOD PER 100ML | | / | | | |
| | TOTAL E-COLI COUNT | | / | | | |
| | BY COLONY COUNT METHOD | | / | | | |

REMARKS:-

The provided water sample found satisfactory as per the applied tests.

Neelam Analyst
Municipal Corporation
16/3/23



Rachna
Mrs. Rachna Monga
Principal
Sanskriti KMV School
Vidyalaya Marg, Tanda Road
Jalandhar

Hehal
SECRETARY
SANSKRITI KMV SCHOOL
JALANDHAR

OFFICE OF CIVIL SURGEON, JALANDHAR

NO:...../159.....

Date.....12/14/2023.....

TO WHOME IT MAY CONCERN

It is certified that team of Health Inspector inspected the premises of Sanskriti KMV School, KMV Campus Tanda Road, Jalandhar on the basis of the report given by the Team, it is certified that the hygiene condition of the Sanskriti KMV School, KMV Campus Tanda Road, Jalandhar are good at Present.


Civil Surgeon, Jalandhar.



Mrs. Rachna Monga
Principal
Sanskriti KMV School
Vidyalaya Marg, Tanda Road
Jalandhar



SECRETARY
SANSKRITI KMV SCHOOL
JALANDHAR

8